

# Batch Test Certificate - Plastic Tipped Wire Bar Chair

AS/NZS2425:2015  
Strength Grade >200Kg



MB Direct 10-12 Ilda Rd Canning Vale WA 6155



supporting the construction industry

Name	DT	Deflection under load	Permanent set
Parameters			
Pass/Fail	198 - 202	-3 - 3	-2 - 2
Unit	mm	mm	mm
1_1	200.954	1.69876	-0.5135

Batch Number	MB1906242001
Product Code	BC200
Batch Total Qty	7500
Report Date	9/08/2019
Test Date	1/08/2019
Test Temperature	23
Testing Machine	AGS-X
Machine No.	I33065130105
Test File Name	BC200_20190801_0959.xtas



MB Direct is an associate member of the SRIA.

Batch numbers are detailed on individual bags, please confirm batch number and product type when requesting batch test certificates.

MB Direct can also issue a generic statement of compliance for any of its product ranges.

This batch Test certificate is NOT to be altered or adjusted in anyway without prior written consent of MB Direct.

If you require any additional clarification please contact MB Direct via [sales@mbdirect.com.au](mailto:sales@mbdirect.com.au)

[www.mbdirect.com.au](http://www.mbdirect.com.au)